



Manage our Resources



Explore Innovative Solutions



Protect our Environment



Preserve our Community

CITY OF PORTSMOUTH WASTEWATER DIVISION

PEIRCE ISLAND FACILITIES UPGRADE

CITY COUNCIL WORKSHOP

APRIL 8, 2013

Topics for Discussion

- Introduction
- History
- Wastewater Master Plan
- Technology Selection Pilot Study
- Current Alternatives
- Next Steps
- Questions and Comments



History

- 1964 – Original Peirce Island WWTF Built
- 1980 - Secondary Treatment Plant was Designed
- 1982 - State Prepares 301(h) Waiver State and City Jointly Submit to EPA
- 1985 – NPDES Permit Issued w/301(h) Waiver
- 1987 - RSA – 149-B:1 - 95% State and Federal Funding
- Peirce Island WWTF Upgraded in 1990, 2002 as Advanced Primary Treatment
- 2005 - Draft Permit Issued by EPA with 301(h) Waiver – Appealed
- 2007 - New Permit Issued with Secondary Requirements



Public Process History

- During the Course of this Process, Have Given Over 40 Presentation on this Topic Including:
 - Wastewater 101 and 202
 - Numerous Quarterly Updates
 - Council Briefings and Public Input Sessions
 - Council Retreats
 - City-wide Neighborhood Association Meetings
 - Pilot Open House
 - City Wastewater Master Plan Website (www.portsmouthwwmp.com)



Wastewater Master Plan's Two Components




Collection System -
Combined Sewer Overflows
(CSO) Long Term Control
Plan (LTCP)

Wastewater Treatment Facilities



Master Planning Goal

- Master Planning effort to ensure the selected treatment plant and collection system CSO LTCP alternatives would be:
 - Sustainable
 - Cost effective
 - Environmentally sound
 - Fulfills regulatory requirements
 - Fulfills funding requirements



Wastewater Master Plan

- Development was not Driving Force for the Wastewater Master Plan
- Master Plan to Determine:
 - Current and projected flows and loads
 - Extent of regional involvement
 - Regulatory requirements
- Lay Ground Work to Size and Select Appropriate Technologies for New Treatment Plant and Collection System CSO LTCP Upgrades




Wastewater Master Plan Alternatives Assessment

- **WMP Alternatives Assessment to Include:**
 - Collection system CSO mitigation strategies
 - Treatment plant upgrade options
 - Type of treatment technology
 - Plant location




Potential Wastewater Treatment Facility Locations



- Lot Size
- Ownership
- Protected Land
- Proximity to Residential Areas
- Proximity to River



Alternative Locations



PEIRCE ISLAND FACILITIES UPGRADE

Potential Plant Alternatives

- Over 30 Alternatives Evaluated
- Throughout WMP Process Meetings were Held with Regulators and Non Governmental Groups
- Treatment Plant Upgrade Alternatives
 - Expand the Peirce Island plant
 - Expand the Pease plant
 - Construct a new plant at a new location
 - Combination of redirecting flow and plant expansion/upgrade
- Each Alternative Impacts the Collection System CSO LTCP



Draft Wastewater Master Plan Alternatives

- Phased Expansion of Pease WWTF – Redirection of all the City's Sanitary Flow Over 15 Years, Incremental Expansion of the Existing Pease WWTF
- Peirce Island WWTF Upgrade - Upgrade of the Existing Peirce Island Chemically Enhanced Primary Treatment (CEPT) System to a Secondary Process with Nutrient Removal



Preferred Alternative Submitted to EPA in July 2010

- Upgrade Pease WWTF to 8 mg/L Total Nitrogen
- Phased expansion Over 15 Years
- Use the Existing Pease WWTF Outfall Location



EPA/NHDES Response to July 2010 Draft WMP Submission

- Draft WMP Schedule did not Achieve Secondary Treatment Quickly Enough
- Affordability Issues do not Warrant an Extended Schedule
- EPA Required City to Achieve Secondary Treatment of Peirce Island Flows in next 5-7 Years (i.e. 2017)
- EPA Required Preliminary Engineering and Pilot Study to be Underway by July 1, 2011



Following the EPA/DES Response to Draft Submission

- Final Submission Date Extended to November 15, 2010
- Development of Alternative Compliance Strategy on Peirce Island
- Preliminary Engineering Efforts Including Pilot Testing of Potential High Rate Treatment Technologies



Revised Wastewater Master Plan

- Included Timeline to Meet Secondary Treatment at Peirce Island (EPA incorporated into Consent Decree)
 - Evaluate high rate treatment technologies options
 - Pilot appropriate treatment technology
 - Permitting
 - Design
 - Bidding
 - Construction
- Continue to Implement Long Term Control Plan Measures



City Council Meeting, November 8, 2010

- Revised Wastewater Master Plan presented to City Council

Revised plan summarized as follows: “we are looking for a viable plan to implement secondary treatment at Peirce Island within the fence line.”

- Council voted: “to authorize the City Manager to submit its final Wastewater Master Plan to EPA”
- Final Supplement Wastewater Master Plan submitted to EPA November 15, 2010



Questions



PEIRCE ISLAND FACILITIES UPGRADE

Pilot Study

preserve our community protect our environment manage our resources explore innovative solutions

City of Portsmouth
Wastewater Master Plan
Phase 2 Initial Piloting Technical Memorandum
Volume One • September, 2012

Portsmouth Department Of Public Works
Wastewater Master Plan Piloting Evaluation
**WASTEWATER TREATMENT
TECHNOLOGY PERFORMANCE
EVALUATION PROJECT**
This project is the City's best step in selecting
the most cost effective solution for providing
secondary treatment at the Peirce Island WWTP.
The submerged tanks are scaled down versions
used to test and evaluate treatment performance
for three potential technologies under consideration.

AECOM



PEIRCE ISLAND FACILITIES UPGRADE

Pilot Study

- Upgrading PI WWTF While Staying Within Existing Fence-line Required Use of Small Footprint, High Rate Emerging Treatment Technologies
- Technologies Were Piloted to :
 - Define technology performance under varying flow and load conditions and assess capacity for each technology
 - Determine the ability to upgrade to meet future nutrient requirements
 - Identify operational and maintenance factors specific to each technology
 - Confirm Manufacturer/Vendor sizing criteria and space requirements to provide secondary treatment for each technology



Why Pilot?

Piloting will Avoid the Situation that Occurred with the Existing Filter Building



Pilot Technology Screening Criteria

- Capital Costs
- Life Cycle Costs
- Operational Track Record/Established Process
- Operability (No. of Processes/Complexity of Processes)
- Ability to Retrofit to Meet Future Permit Limits
- Constructability
- Site Layout Hydraulic Complexity
- Ability to Stay Within Fence Line
- Ability to Treat High FOG Levels



Technologies Selected for Piloting

- From the Eight Technologies Evaluated
 - Biological Aerated Filter (BAF)
 - Conventional Activated Sludge with BioMag (CASB)
 - Moving Bed Bioreactor (MBBR) and Dissolved Air Flotation (DAF)
- Initially Pilot Units Were Configured for Secondary Treatment
- Pilot Units Were Reconfigured for Nitrogen Removal





Lessons Learned During Pilot Study

- Wastewater Characteristics are Changing due to Success of Sewer Separation Projects
- Consent Decree Requires Secondary Treatment
EPA is now Indicating that City Permit will Include a Nutrient Limit of 8 mg/L
- EPA and City are in Discussions Over Treatment Plant Capacity
 - Why is this Important
 - Additional tanks and capital costs
 - Additional operations and maintenance costs



Pilot Study Summary

- All Piloted Technologies Meet Secondary and Total Nitrogen Limit of 8 mg/L
- At a Total Nitrogen Limit of 8 mg/L, Initial Layout of All Three Technologies are Outside the Existing Plant Fence Line
- Given the Lessons Learned from Pilot Study Previously Screened Technologies Should be Revisited to Confirm Final Selection
- Regulatory Uncertainty Impacts Design and may Impact Schedule



Initial Pilot Recommendations

- Biological Aerated Filter Sized to Meet Secondary Treatment Standards with the Ability to Meet a Total Nitrogen Limit of 8 mg/L
- Treat Annual Average of 6.13 Million Gallons per Day Through BAF
- Treat Maximum Day Flow of 9.06 Million Gallons per Day Through BAF
- Treat Excess Wet Weather Flows Through Chemically Enhanced Primary Clarifiers




Questions



PEIRCE ISLAND FACILITIES UPGRADE


Proposed Process Flow Schematic



- Size of Plant: 9.06 mgd Maximum Day Flow to Secondary Treatment
- Measure of Compliance: 8 mg/L Total Nitrogen Seasonal Rolling Average on Blended Effluent



Seasonal Rolling Average



Current Alternatives



Biological Aerated Filter

Conventional Activated Sludge




Existing Site




PEIRCE ISLAND FACILITIES UPGRADE

Site Constraints




Initial Layout Biological Aerated Filter - \$60.5M



PEIRCE ISLAND FACILITIES UPGRADE

Revised Biological Aerated Filter Layout - \$61M



Revised Biological Aerated Filter Layout - \$61 M



PEIRCE ISLAND FACILITIES UPGRADE

Existing Site




PEIRCE ISLAND FACILITIES UPGRADE

Biological Aerated Filter Rendering




PEIRCE ISLAND FACILITIES UPGRADE

Conventional Activated Sludge - \$57M



Conventional Activated Sludge - \$57M



PEIRCE ISLAND FACILITIES UPGRADE

Existing Site



PEIRCE ISLAND FACILITIES UPGRADE

Conventional Activated Sludge Rendering



PEIRCE ISLAND FACILITIES UPGRADE

Advantages/Disadvantages

Process	Advantages	Disadvantages
<p style="text-align: center;">Conventional Activated Sludge (CAS)</p>	<ul style="list-style-type: none"> • Lowest Initial Capital Cost • Lowest O&M Cost • Commonly Used Technology • Not a Proprietary Process • Longer Operating History • Easier to Operate • Reduced Solids Handling Costs 	<ul style="list-style-type: none"> • Larger Footprint – Outside Fence • Increased Potential for Site Permitting Challenges • Additional Capital Upgrade Needed to Achieve Lower Nitrogen Limits • Performance Deteriorates at Higher Flow
<p style="text-align: center;">Biological Aerated Filter (BAF)</p>	<ul style="list-style-type: none"> • Smaller Footprint – Inside Fence • No Additional Capital Cost Required to Achieve Lower Nitrogen Limits • Vendor Performance Guarantee • Robust Cold Weather Operation • Less Susceptible to High Flow Washout 	<ul style="list-style-type: none"> • Higher Initial Capital Cost • Higher O&M Cost • Fewer Operating Installations (333 total world wide, 38 in North America) • More Mechanical Equipment • Proprietary Process



Comparison of Estimated Costs

Process	Projected Capital Cost	20 Year Life Cycle Cost
Conventional Activated Sludge (CAS)	\$57.0	\$68.6
Biological Aerated Filter (BAF)	\$61.0	\$75.6

Note: All Costs in \$ millions

Costs Include Engineering and Contingencies

Based on a seasonal rolling average limit of 8 mg/L TN

Assumes no changes in permit limits over the next 20 years



Comparison of Costs for Future Permit Limits

Process	Projected Initial Capital Cost	Projected Future Capital Cost	20 Year Life Cycle Cost
Conventional Activated Sludge (CAS)	\$57.0	\$16.5	\$87.4
Biological Aerated Filter (BAF)	\$61.0	-	\$76.5

Note: All Costs in \$ millions

Costs Include Engineering and Contingencies

Assumes change in permit limit from seasonal average TN of 8 mg/L to seasonal average TN of 3 mg/L after 5 years



Current Status

- Final Design
- Continued Regulatory Uncertainty
 - Seasonal rolling average of 8 mg/L total nitrogen
 - Plant capacity of 9.06 MGD
 - Construction schedule



PI WWTF Consent Decree Deadlines

<i>Item</i>	<i>Consent Decree Deadline</i>	<i>Project Status</i>
<i>Complete Pilot Testing</i>	<i>6/30/12</i>	<i>Complete</i>
<i>Submit Pilot Memo</i>	<i>10/1/12</i>	<i>Complete</i>
<i>Begin Final Design</i>	<i>7/1/13</i>	<i>In Progress</i>
<i>Complete Final Design</i>	<i>8/31/14</i>	<i>Pending</i>
<i>Begin Construction</i>	<i>3/1/15</i>	<i>Pending</i>
<i>Complete Construction</i>	<i>3/1/17</i>	<i>Pending</i>
<i>Achieve Compliance</i>	<i>5/1/17</i>	<i>Pending</i>



Major Project Considerations

- Site Constraints/Permitting
- Odor Control
- Regulatory Issues
- Consent Decree Schedule
- Communication
- Plant Operation During Construction
- Reduce Project Cost



Questions and Answers



PEIRCE ISLAND FACILITIES UPGRADE