

**CITY OF PORTSMOUTH
DEPARTMENT OF PUBLIC WORKS
INTEROFFICE MEMORANDUM**

To: Peter Rice, ^{ESF} Eric Fiedler, Zach Cronin
CC: Brian Goetz , Peter Conroy, Jim Tow, Shane Nichols
From: Karl Snyder
Date: July 07, 2023
RE: CSO 10A and CSO 10B and CSO Deer Street – Results

See attached CSO flow monitoring and rainfall results for June 2023 to be attached to the DMR report for the Peirce Island WWTF. Note the rainfall related CSO events for:

CSO 10A
06/17/2023 Volume = 0.014 MG* Rain 1.320 Inches
TOTAL Volume = 0.014 MG*

CSO 10B
There were no overflows for the month of June 2023

DEER STREET OVERFLOW
There were no overflows for the month of June 2023

*Million Gallons

City of Portsmouth, NH

Department of Public Works Combined Sewer Overflow Summary Report June 2023 NPDES Permit No. NH 01000324

Time	CSO 010A Daily Flow (MG)	CSO 010B Daily Flow (MG)	CSO 013 Daily Flow (MG)		RG City Hall Daily Rain (in)	
6/1/2023	0.000	0.000	0.000		0.000	
6/2/2023	0.000	0.000	0.000		0.170	
6/3/2023	0.000	0.000	0.000		0.150	
6/4/2023	0.000	0.000	0.000		0.100	
6/5/2023	0.000	0.000	0.000		0.060	
6/6/2023	0.000	0.000	0.000		0.000	
6/7/2023	0.000	0.000	0.000		0.040	
6/8/2023	0.000	0.000	0.000		0.000	
6/9/2023	0.000	0.000	0.000		0.000	
6/10/2023	0.000	0.000	0.000		0.060	
6/11/2023	0.000	0.000	0.000		0.000	
6/12/2023	0.000	0.000	0.000		0.020	
6/13/2023	0.000	0.000	0.000		0.340	
6/14/2023	0.000	0.000	0.000		0.160	
6/15/2023	0.000	0.000	0.000		0.010	
6/16/2023	0.000	0.000	0.000		0.060	
6/17/2023	0.014	0.000	0.000		1.320	
6/18/2023	0.000	0.000	0.000		0.100	
6/19/2023	0.000	0.000	0.000		0.000	
6/20/2023	0.000	0.000	0.000		0.120	
6/21/2023	0.000	0.000	0.000		0.000	
6/22/2023	0.000	0.000	0.000		0.000	
6/23/2023	0.000	0.000	0.000		0.000	
6/24/2023	0.000	0.000	0.000		0.030	
6/25/2023	0.000	0.000	0.000		0.000	
6/26/2023	0.000	0.000	0.000		0.590	
6/27/2023	0.000	0.000	0.000		0.080	
6/28/2023	0.000	0.000	0.000		0.320	
6/29/2023	0.000	0.000	0.000		0.010	
6/30/2023	0.000	0.000	0.000		0.000	
TOTALS	0.014	0.000	0.000	[MG]	3.740	(IN)