

September 1, 2010

Addendum #1
For
Bid # 10-11
South Mill Street & Mechanic Street Seawall
Reconstruction

This addendum forms part of the original document marked: Bid #10-11 South Mill Street & Mechanic Street Seawall Reconstruction.

The following clarifications and addenda are issued:


1. Pile Head Detail

The attached detail is to clarify the double angles on each pile head. The 12" long angles are field welded to the outer faces of the pile flanges (tack weld to the pile).

Mechanic Street Seawall Pile Head Detail drawing is on the following page.

Please acknowledge receipt of this addendum within your proposal. Failure to do so may cause a bidder to be disqualified.

MECHANIC ST SEAWALL PILE HEAD DETAIL
SEPT. 1, 2010



PILE HEAD DETAIL

