

City of Portsmouth, NH Department of Public Works

ADDENDUM No. 2

RFQ#39-20

**Design Engineering Services for
Pease Wastewater Treatment Facility (WWTF) Aeration Blower Upgrade**

Issued: July 2, 2020

This Addendum becomes part of the original document marked RFQ #39-20 Design Engineering Services for Pease WWTF Aeration Blower Upgrade.

RESPONSES TO QUESTIONS

The question and answer period ended July 1, 2020. The following questions were received:

Question: Can you please provide a year of energy consumption data for the Pease WWTF?

Answer: See table below for a year of data.

DATE	ENERGY CONSUMPTION (KWH)
May 2019	82,800
June 2019	83,200
July 2019	78,000
August 2019	85,200
September 2019	69,000
October 2019	74,400
November 2019	74,000
December 2019	79,800
January 2020	85,600
February 2020	80,600
March 2020	81,200
April 2020	73,400
May 2020	78,800

All else remains as is.

Respondents are to acknowledge this addendum within their proposal. Failure to do so may subject a respondent to disqualification.

End of Addendum #2