

CITY OF PORTSMOUTH

Bid 58-17

Middle School Chiller

Addendum #1

Issued: May 22, 2017

This Addendum forms part of the original document marked: Bid 58-17 Middle School Chiller.

The following questions have been asked and answered:

Q. Are as-built drawings of the existing chiller installation available in PDF format?

A: *There is no as-built drawing for second PMS chiller.*

Q: We understand that a new chilled water pump will be provided as part of this work, however no manufacturer or capacity information is in the bid package. Is there a schedule available for this equipment?

A: *Second Chiller Pump is already in place with VFD. Awarded contractor will need to finish piping to complete tie in.*

Q: There was some discussion at the walkthrough about a quick ship option for the new chiller. Will a new bid form be issued that includes this as an alternate?

A: *There will be no alternate pricing request for quick ship option. Please provide pricing as requested.*

Attached is the list of attendees at the mandatory pre-bid meeting held on May 12, 2017.

All else remains unchanged from original Bid document.

Please acknowledge this addendum within your proposal, failure to do so may subject a bidder to disqualification.

END OF ADDENDUM #1

