

ADDENDUM #2

THIS ADDENDUM FORMS PART OF THE ORIGINAL DOCUMENT MARKED:
Chemical Sheds Roofing and Siding
BID #09-22

Please acknowledge receipt of this Addendum with your proposal.

CHANGES AND CLARIFICATIONS:

PROPOSAL FORM

Page 9, SUMMARY OF WORK, A. Large Chemical Shed

Delete Work item 1. And replace with:

1. Remove and replace:
 - a. 6 existing damaged roof panels
 - b. 30 lf of ridge cap
 - c. 30 lf of drip edge

Delete Work item 7. And replace with:

7. Power wash, prime and paint 2 coats latex on concrete foundation walls.

SPECIFICATIONS

SECTION 074113, SECTION 1.1 REQUIREMENTS.

Delete paragraph A and replace with:

- A. Replace the following metal roof items to match existing:
 1. Six sections of factory formed metal roof panels
 2. 30 lf of metal ridge cap
 3. 30 lf of metal drip edge

SECTION 099100, 1.1 REQUIREMENTS

Delete paragraph A.2 and replace with:

2. Powerwash, clean and paint concrete foundation walls per MPI 3.1

END OF ADDENDUM 2