

FIGURE ES-1

LEGEND

- Meter Pits
- PRV
- PIV
- Pump Station
- Well
- Tank
- Water Treatment Plant
- Town Line

Progress

- 12" DI, Installed
- 12" DI, Proposed for 2013
- 16" DI, Installed
- 8" DI, Installed
- 8" DI, Proposed for 2013

Water Main

- <6"
- 6"
- 8"
- 10"
- 12"
- 14"
- 16"



Transmission Main

- 20-24"

Future Work

- Future Work
- Major Roads

LOCUS MAP



NOTES


Data sources:
 New Hampshire Geographically Referenced Analysis and Information Transfer System (GRANIT)
 City of Portsmouth, New Hampshire

**Portsmouth Water System
 Portsmouth, New Hampshire**

FEBRUARY 2013



**Figure ES-4
Recommended
Water Distribution
Projects**



- Proposed Water Main
- Water Main
- Water Main
- PS Pump Station
- W Well
- Tank
- X PRV
- PIV
- WTP WTP

Location/ Scenario	Estimated Project Cost	Location/ Scenario	Estimated Project Cost
G-1	\$600,000	NC-7	\$340,000
N-1	\$760,000	NC-14	\$2,640,000
N-2	\$220,000	PE-2a	\$2,760,000
N-3	\$1,310,000	PO-1b	\$3,300,000
N-4	\$420,000	PO-5	\$340,000
NC-1	\$100,000	PO-7b	\$360,000
NC-4	\$810,000	PO-8	\$100,000



Portsmouth Water System
Portsmouth, New Hampshire
February 2013

Notes

1. The Pease WTP is only used if triggered by VOC levels in monitoring wells.

LEGEND

- Direction of Flow
- PRV Pressure Regulating Valve
- PS Pump Station
- ST Storage Tank
- W Well
- Pressure Zone Elevation




Figure 3-1 Distribution System Schematic - The Portsmouth Water System

VERTICAL DATUM: USGS
HORIZONTAL SCALE: NOT TO SCALE

February 2013

The City of Portsmouth, NH



Figure 3-8
Model Predicted
Available Fire Flow
Maximum Day Demand
(July 21-22, 2011
System Demand: 6.7 MG)

Model Predicted
Available Fire Flow (gpm)


- <500
- 501 - 1000
- 1001 - 2000
- 2001 - 3000
- 3001 - 3500
- >3500

- Water Main
- PS Pump Station
- W Well
- T Tank
- PRV PRV
- PIV PIV
- WTP WTP



Tighe & Bond

Portsmouth Water System
 Portsmouth, New Hampshire
 February 2013




**Figure 3-9
Model Predicted
Available Fire Flow
Downtown Area
Maximum Day Demand
(July 21-22, 2011
System Demand: 6.7 MG)**

**Model Predicted
Available Fire Flow (gpm)**

- <500
- 501 - 1000
- 1001 - 2000
- 2001 - 3000
- 3001 - 3500
- >3500


- Water Main
- PS Pump Station
- W Well
- T Tank
- PRV
- PIV
- WTP



Tighe & Bond

Portsmouth Water System
Portsmouth, New Hampshire
February 2013

**Figure 3-10
Model Predicted
Minimum Pressure
Maximum Day Demand
(July 21-22, 2011
System Demand: 6.7 MG)**



**Model Predicted
Minimum Pressure (psi)**

- <20
- 21 - 35
- 36 - 45
- 46 - 55
- >55


- Water Main
- PS Pump Station
- W Well
- Tank
- PRV
- PIV
- WTP



Tighe & Bond

Portsmouth Water System
Portsmouth, New Hampshire
February 2013

Figure 3-11
Model Predicted
Minimum Pressure
Downtown Area
Maximum Day Demand
(July 21-22, 2011
System Demand: 6.7 MG)



Model Predicted
Minimum Pressure (psi)

- <20
- 21 - 35
- 36 - 45
- 46 - 55
- >55


- Water Main
- PS Pump Station
- W Well
- T Tank
- ⊗ PRV
- PIV
- WTP WTP



Tighe & Bond

Portsmouth Water System
 Portsmouth, New Hampshire
 February 2013

**Figure 3-12
Maximum Model
Predicted Velocity
Maximum Day Demand
(July 21-22, 2011
System Demand: 6.7 MG)**



**Model Predicted
Velocity (ft/s)**

- <0.10
- 0.11 - 0.20
- 0.21 - 0.40
- 0.41 - 1.00
- >1.00


- Pump Station
- Well
- Tank
- PRV
- PIV
- WTP



Tighe & Bond

Portsmouth Water System
Portsmouth, New Hampshire
February 2013

**Figure 3-13
Maximum Model
Predicted Head Loss
Maximum Day Demand
(July 21-22, 2011
System Demand: 6.7 MG)**



**Model Predicted
Head Loss (ft) per
Thousand Feet**

- <0.01
- 0.02 - 0.05
- 0.06 - 0.10
- 0.11 - 0.25
- >0.25


- Pump Station
- Well
- Tank
- PRV
- PIV
- WTP



Tighe & Bond

Portsmouth Water System
Portsmouth, New Hampshire
February 2013

**Figure 3-14
Model Predicted
Water Age
Average Day Demand
4:00 PM
(May 22-23, 2011
System Demand: 4.5 MG)**



**Model Predicted
Water Age (hrs)**

- <15
- 16 - 30
- 31 - 100
- >100


- PS Pump Station
- W Well
- T Tank
- ⊗ PRV
- PIV
- WTP WTP



Tighe&Bond

Portsmouth Water System
Portsmouth, New Hampshire
February 2013

**Figure 3-15
Model Predicted
Surface Water
Distribution
Baseline Scenario
Average Day Demand
(May 22-23, 2011
System Demand: 4.5 MG)**



**Model Predicted
Surface Water
Contribution (%)**


- <20%
- 20 - 40%
- 40 - 60%
- 60 - 80%
- >80%
- PS Pump Station
- W Well
- T Tank
- X PRV
- PIV
- WTP WTP



Tighe & Bond

Portsmouth Water System
Portsmouth, New Hampshire
February 2013

**Figure 3-16
Model Predicted
Surface Water
Distribution
Reduced Surface
Water Contribution
Average Day Demand
(May 22-23, 2011
System Demand: 4.5 MG)**




**Model Predicted
Surface Water
Contribution (%)**

- <20%
- 20 - 40%
- 40 - 60%
- 60 - 80%
- >80%
- PS Pump Station
- W Well
- T Tank
- X PRV
- PIV
- WTP WTP



Tighe & Bond


Portsmouth Water System
Portsmouth, New Hampshire
February 2013



- Proposed Pressure Area
- Proposed Water Main
- Existing Water Main
- PS Pump Station
- W Well
- T Tank
- WTP WTP
- X PRV
- PIV


Figure 3-17
Greenland, Pease, and Newington
Water System Alternatives



Tighe & Bond
 Portsmouth Water System
 Portsmouth, New Hampshire
 February 2013



- Existing Water Main
- Proposed Water Main
- Pump Station
- Well
- Tank
- PRV

Figure 3-18
Portsmouth Water System Alternatives


Tighe & Bond
 Portsmouth Water System
 Portsmouth, New Hampshire
 February 2013




**Figure 3-20
New Castle Water
System Alternatives**

- Water Main
- Water Main Improvement
- PS Pump Station
- W Well
- Tank
- PRV
- Remove Meter Pit



Portsmouth Water System
Portsmouth, New Hampshire
February 2013

**Figure 4-1
Recommended
Water Distribution
Projects**



- Proposed Water Main
- Water Main
- Water Main
- PS Pump Station
- W Well
- Tank
- X
 PRV
- PIV
- WTP WTP

Location/ Scenario	Estimated Project Cost	Location/ Scenario	Estimated Project Cost
G-1	\$600,000	NC-7	\$340,000
N-1	\$760,000	NC-14	\$2,640,000
N-2	\$220,000	PE-2a	\$2,760,000
N-3	\$1,310,000	PO-1b	\$3,300,000
N-4	\$420,000	PO-5	\$340,000
NC-1	\$100,000	PO-7b	\$360,000
NC-4	\$810,000	PO-8	\$100,000



Portsmouth Water System
Portsmouth, New Hampshire
February 2013